

SANITARY CONDITION CERTIFICATE

Letter No. 89

Date 05.02.2025

It is certified that an inspection team headed by I.C.M.O. & Sanitary Inspector
P.H.C. Sadar Block Siwan. (Name of Officer with designation)
from Health Dept. (Name of Department/ Office inspected the
Mahaviri Saraswati Vidya Mandir Goshala Road, Vijayhata, Siwan (Bihar) ,
Pin - Code - 841227 on 01.02.2025 and

Found that the Mahaviri Saraswati Vidya Mandir (Name of School) is
Goshala Road Vijayhata Siwan.

Maintaining the hygienic sanitation condition in the school building &

campus as per the norms prescribed by the Central/State/U.T

Government.

Above Certificate is valid for a period of One Year.

Uday Sharma
5.2.2025

Attested
Principal
M.S.V.M.
Vijayhata, Siwan

[Signature]
Signature with seal

Name Incharge Medical Officer
P.H.C. Sadar Block
Designation Siwan

To

Mahaviri Saraswati Vidya Mandir,

At:- Goshala Road, Vijayhata, Siwan
(Bihar), Pin-Code -841227



कार्यालय : 'असैनिक शल्य चिकित्सक-सह-मुख्य चिकित्सा पदाधिकारी, सिवान।

Telephone No.- 06154-242782 Email:- cssiwan@gmail.com Mobile No- 9470003788



पत्रांक 323/

प्रमाण-पत्र

सिवान दिनांक 17.02.2025

डा० मो० नेसार, प्रभारी चिकित्सा पदाधिकारी, प्राथमिक स्वास्थ्य केन्द्र, सदर प्रखण्ड, सिवान एवं श्री उदय शंकर, स्वच्छता निरीक्षक, प्राथमिक स्वास्थ्य केन्द्र, सदर प्रखण्ड, सिवान द्वारा संयुक्त रूप से दिनांक 01.02.2025 को महावीरी सरस्वती विद्या मंदिर, गौशाला रोड़, विजय हाता, सिवान के परिसर की साफ-सफाई एवं छात्र-छात्राओं एवं पदस्थापित कर्मियों के लिए पीने के पानी की जाँच की गई, जिसे स्वच्छ पाया गया, साथ ही प्राथमिक उपचार की व्यवस्था पायी गई।

यह प्रमाण-पत्र निर्गत तिथि से एक वर्ष के लिए मान्य होगा।

अनुलग्नक :- प्रमाणपत्र ।

Attested
Principal
M.S.V.M.
Vijayhata, Siwan

असैनिक शल्य चिकित्सक-सह-
मुख्य चिकित्सा पदाधिकारी, सिवान
17/02/2025



Govt. of Bihar
District Water Testing Laboratory
PHED, Siwan
TEST REPORT

DOC NO : SWN /SAMP/05/00

Name & Address Of the Customer : Mahaviri sarasawati vidyamandir, Mahavirpuram, Gaushala Road, Vijayhata Siwan	Report No.	SWN/W/24-25/R/ 56
	Date of Reporting	25.01.2025
	Sample No.	SWN/W/24-25/56
	Sample Description	Drinking Water
	Sample Mark/ Location	
	Sample Submitted in Lab On	23.01.2025
	Sampling Plan & Method	IS 17614 (Part 1): 2021
	Date of Completion of Test	25.01.2025
	Ref No. Date	

Analysis Result

Sl. No.	Test Parameter	Test Method	IS 10500:2012Amd. 1 & 2		Result
			Acceptable Limit	Permissible Limit	
1	Colour (HU)	IS 3025 (Part 4) : 2021	5	15	<5
2	Odour	IS 3025 (Part 5) : 2022	Agreeable	NR	Agreeable
3	Taste	IS 3025 (Part 8) : 2023	Agreeable	NR	Agreeable
4	pH at 25 °C	IS 3025(Part 11) : 2022	6.5	8.5	7.09
5	Turbidity (NTU)	IS 3025(Part 10) : 2023	1	5	<1
6	TDS (mg/l)	IS 3025(Part 16) : 2023	500	2000	419
7	Total Hardness (mg/l)	IS 3025(Part 21) : 2023	200	600	163.40
8	Calcium (mg/l)	IS 3025(Part 40) : 2023	75	200	48.64
9	Magnesium (mg/l)	APHA 24th Addition-3500-Mg Method B : 2023	30	100	10.15
10	Chloride (mg/l)	IS 3025(Part 32) : 2019	250	1000	75.760
11	Total Alkalinity (mg/l)	IS 3025(Part 23) : 2023	200	600	181.28
12	Iron (mg/l)	APHA 24th Edition -3500-Fe Method B : 2023	1.00	NR	0.249

End Of Report

Disclaimer:


- The result relates only to the item(s) tested.
- The report shall not be reproduced except in full, without approval of the laboratory.
- The reserved part of water sample(s) shall be retained for 15 days from the date of issue of the report.
- The results apply to the sample as received.

For District Water Testing Laboratory, PHED, Siwan
Reviewed & Authorized By

Attested

Principal
M.S.V.M.
Vijayhata, Siwan




27-01-2025
Name : Mrs. Brihaspati Yadav
(Authorized Signatory)